

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20170715, Building Permit - Residential

Address: 3352 SW JESSIE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Dale Carter	Passed	Thursday, October 19, 2017

All Rough Inspection - Residential	Dale Carter	Failed	Thursday, October 19, 2017
---	-------------	--------	----------------------------

Corrective Action Required

1	Misc	REMOVE OVERGROWN WEEDS BEFORE FURTHER INSPECTION.
		8. ATTIC: Slope DWV. *Sloped; now needs support. (Over laundry.)
		OK to insulate.

Comments: