

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161178, Building Permit - Commercial

Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Partial	Thursday, October 19, 2017

Partial Correction

1 Misc

PEDESTAL ELECTRICAL SERVICES FOR PARKING LOT LIGHTING
CONTROL PANELS:

- **RELEASE 1800-LC1**

- **RELEASE 1800-LC2**

Underground Electrical Inspection - Commercial	John Borns	Partial	Thursday, October 19, 2017
---	------------	---------	----------------------------

Partial Correction

1 Misc

OK TO POUR WHEN READY LIGHT POLE BASES AT FOLLOWING
LOCATIONS NUMBERED ON SITE PLAN IN PERMIT PRINT SET: #1
THRU #35; **[36-39;**

Partial Correction

2 Misc

OK TO COVER WHEN READY TRENCHED PVC CONDUIT: FROM
L.P.#2 ONE 1" TO 80' WEST + ONE 3/4" TO 28' WEST CONN TO
EXSTG; ONE 1" FROM PL#2 TO 45' NE FOR BL; ONE 1" ~80'
ACROSS FRONT ENTRANCE FROM BL TO BL; ONE 3/4" FROM LP#7
~110' NW FOR BL; ONE 1" FROM PL#7 NORTH 20' TO Q-BOX
LOCATION; ONE 1" FROM Q-BOX LOCATION NW TO BL LOCATION
EAST OF ENTRANCE CANOPY; GROUND ROD FOR LP#7 LAID IN
CONDUIT TRENCH DUE TO ROCK CONDITIONS; FROM L.P.#10 TO
#11 TO #12; #13 TO #9 TO #10; FROM #12 TO #14 TO #15; FROM
#6 TO 15' WEST; 1" PVC FROM #17 TO 26 TO 25 TO 24 TO 23 TO
22 TO 21; TWO 1" FROM 29 WEST/NW TO PEDESTAL METER; ONE

1" PVC FROM NW CORNER OF POOL BLDG TO 100' WEST - FROM THIS POINT TO STUB-UP AT BUILDING A; FROM STUB-UP AT BUILDING A EAST TO BOLLARD LIGHT #D2; FROM BOLLARD LIGHT #D2 TO A POINT 20' TO THE NORTH; CONDUIT COMPLETE AND CONNECTED IN AREA OF SITE LIGHTING METER PEDESTAL, L.P. BASE AND QUAZITE BOX N OF BLDG "B"; ONE 1" PVC FROM INSIDE-CORNER OF PATIO TO WEST OF POOL BLDG, EAST ALONG NORTH SIDE OF PATIO; ONE 1" PVC FROM NORTH SIDE OF COMMONS PATIO TO EAST SIDE OF FIREPIT; FROM NORTH SIDE OF PATIO TO NORTH, AROUND CORNER OF FIREPIT, THEN WEST TO L.P. #D5;

Comments: