

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFR20171746, Public Works Infrastructure Permit - Residential  
Manor at Stoney Creek 2nd - street, storm, sewer and water

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer Construction Inspection	Brice Lawson	Partial	Monday, October 23, 2017

Informational

1 Brice Lawson 10/23/2017 8:52 AM

There has been a revision to sanitary sheet C.406. This revision was due to the location of the existing water main. This revision includes a note to allow the sanitary and water main to have a 5' horizontal separation between the two mains. I asked Gene Williams if this 5' of separation (instead of 10' of separation shown in the Dand C Manual) is acceptable. He is ok with this 5' of separation.

This revision also requires the existing FH 060-119 to be relocated to the south side of the existing water main to avoid the sanitary sewer from being located beneath the fire hydrant.

DEI-Water Line - Fire Hydrant	Brice Lawson	Partial	Monday, October 23, 2017
-------------------------------	--------------	---------	--------------------------------

Corrective Action Required

1 Brice Lawson 10/23/2017 9:26 AM

Relocate FH 060-119 to the south side of the existing water main to avoid the proposed sanitary line being located beneath the fire hydrant.

Comments:

