

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20173357, Building Permit - Commercial

Address: 836 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Commercial</b>	John Borns	Partial	Monday, October 23, 2017

<b>Gas Piping Inspection - Commercial</b>	John Borns	Failed	Monday, October 23, 2017
-------------------------------------------	------------	--------	--------------------------

Corrective Action Required

1	Misc	SECURE RISER TO WALL NEAR TOP
---	------	-------------------------------

**Comments:**