

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20171543, Building Permit - Commercial

Address: 221 NW CHIPMAN RD, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Passed	Monday, October 23, 2017

Electrical Service Inspection - Commercial	John Borns	Failed	Monday, October 23, 2017
--	-----------------------	-------------------	-------------------------------------

Corrective Action Required

1	Misc	REMAINING KNOCKOUTS PREVENT NIPPLE FROM PROVIDING CERTAIN BONDING AT METER ENCLOSURE
---	------	---

Comments: RELEASE SERVICE