



**LEE'S SUMMIT  
MISSOURI**  
**CODE MODIFICATION REQUEST**  
(PLAN REVIEW)

BUILDING/STRUCTURE NAME: Wilshire at Lakewood Memory Care

PREMISE ADDRESS: 3320 NE Wilshire Dr

PERMIT NUMBER (if applicable): PRCOM20160939

OWNER'S NAME: JES

TO: Director of Development Services

In accordance with the Lee's Summit Building Code, I wish to apply for a modification to one or more provisions of the code as I feel that the spirit and intent of the Lee's Summit Building Code are observed the public health, welfare and safety are assured. The following articulates my request for your review and action. (NOTE: ATTACH ANY ADDITIONAL INFORMATION NECESSARY)

Section 304.11 of the 2012 International Mechanical Code requires a guard be provided where mechanical equipment is installed within 10 feet of the edge of a roof. The 2015 and 2018 edition of the IMC, which has been published but not yet adopted by the City of Lee's Summit, allows for the use a fall arrest/restraint anchorage connector device that complies with ANSI/ASSE Z359.1. The owner is requesting the use of the exception found in the newest edition of the IMC.

SUBMITTED BY:

NAME: BRIAN TAPP - FWC

ADDRESS: 200 PEACH WAY

CITY, STATE, ZIP: COLUMBIA, MO 65203

( ) OWNER ☒ OWNER'S AGENT

Tel.# 314-602-4129

SIGNATURE: [Signature]

TRACY DEISTER - ASST. DIRECTOR DEVELOPMENT SERVICES: ☒ APPROVAL ( ) DENIAL

SIGNATURE: [Signature] DATE: 10-23-17

RYAN ELAM - DIRECTOR OF DEVELOPMENT SERVICES: ☒ APPROVED ( ) DENIED

SIGNATURE: [Signature] DATE: 10-29-17

COMMENTS: \_\_\_\_\_

**A COPY MUST BE ATTACHED TO THE APPROVED PLANS ON THE JOB SITE**

3/14/17 M:\CODES ADMIN\FORMS and Handouts\Codes\FORMS\Code Modification Request PLAN REVIEW.doc