

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20170499, Building Permit - Commercial

Address: 910 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Failed	Tuesday, October 24, 2017

### Corrective Action Required

3	Misc	ELECT RECEPTS SHOWN ON APPROVED DRAWINGS AT SALON BASE CABINETS HAVE BEEN CAPPED OFF. INSTALL PER DRAWING AND CODE OR HAVE ENGINEER SUBMIT REVISED DRAWING FOR APPROVAL.
---	------	--

### Corrective Action Required

6	Misc	IFGC 407; 415: PROTECTION OF ROOF MEMBRANE UNDER WOODEN PIPING SUPPORT BLOCKS FOR ROOFTOP EQUIPMENT AND GAS PIPING: <b>COMPLY WITH MAXIMUM SUPPORT SPACING PER IFGC.</b> USE WEATHER-RESISTANT BLOCKING MATERIAL PROVIDING SOLID SUPPORT UNDER PIPE. LOOSE-CLAMP BLOCKS TO PIPE. APPLY SPECIFIED / APPROVED, <b>ROOF-COMPATIBLE SLIP SHEET TO UNDERSIDE OF BLOCKS WITH METAL FASTENERS AT SIDES OF BLOCKS.</b>
---	------	--

### Comments: