

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20171228, Building Permit - Residential

Address: 617 NW LILAC PL, Unit:B, LEES SUMMIT, MO 64081619 NW LILAC PL, LEES SUMMIT, MO
64081615 NW LILAC PL, Unit:B, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	John Borns	Partial	Tuesday, October 24, 2017

Partial Correction

1	Misc	VISUAL INSPECTION AND PRESSURE TEST APPROVED AT UNITS: 615; 619; OK FOR USE.
---	------	---

All Rough Inspection - Residential	John Borns	Partial	Tuesday, October 24, 2017
---	------------	---------	---------------------------

Partial Correction

1	Misc	OK TO INSTALL INSULATION AND GWB AT UNITS: 615; 619; CONTRACTOR NOTE AT UNIT 619: HONEYCOMBED CONCRETE BELOW NORTH END BEARING OF 31' WF STEEL BEAM AT BASEMENT EAST; POSSIBLE BEGINNING OF SHEAR FAILURE. PLEASE CHECK.
---	------	---

Comments: