

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20172853, Public Works Infrastructure Permit - Commercial

Summit Eye Care

Address: 1621 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Wye / Insert-A-Tee Installation	Steve Robbins	Passed	Tuesday, October 24, 2017

Informational

- 1 The service line for the building has been tied into the main with a wye connection using the fernco stainless steel strongback. The tracer wire has been installed along with the trench check. The service line goes under the road and they have had a compaction test done. They are running the tracer wire to the building, they also have the tracer box. They are working on the service line to the building Steve Robbins 10/24/2017 12:04 PM.

Comments: