

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161178, Building Permit - Commercial

Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Wednesday, October 25, 2017

Partial Correction

1	Misc	OK TO POUR WHEN READY LIGHT POLE BASES AT FOLLOWING LOCATIONS NUMBERED ON SITE PLAN IN PERMIT PRINT SET: #1 THRU #41;
---	------	---

Partial Correction

2	Misc	OK TO COVER WHEN READY TRENCHED PVC CONDUIT: FROM L.P.#2 ONE 1" TO 80' WEST + ONE 3/4" TO 28' WEST CONN TO EXSTG; ONE 1" FROM PL#2 TO 45' NE FOR BL; ONE 1" ~80' ACROSS FRONT ENTRANCE FROM BL TO BL; ONE 3/4" FROM LP#7 ~110' NW FOR BL; ONE 1" FROM PL#7 NORTH 20' TO Q-BOX LOCATION; ONE 1" FROM Q-BOX LOCATION NW TO BL LOCATION EAST OF ENTRANCE CANOPY; GROUND ROD FOR LP#7 LAID IN CONDUIT TRENCH DUE TO ROCK CONDITIONS; FROM L.P.#10 TO #11 TO #12; #13 TO #9 TO #10; FROM #12 TO #14 TO #15; FROM #6 TO 15' WEST; 1" PVC FROM #17 TO 26 TO 25 TO 24 TO 23 TO 22 TO 21; TWO 1" FROM 29 WEST/NW TO PEDESTAL METER; ONE 1" PVC FROM NW CORNER OF POOL BLDG TO 100' WEST - FROM THIS POINT TO STUB-UP AT BUILDING A; FROM STUB-UP AT BUILDING A EAST TO BOLLARD LIGHT #D2; FROM BOLLARD LIGHT #D2 TO A POINT 20' TO THE NORTH; CONDUIT COMPLETE AND CONNECTED IN AREA OF SITE LIGHTING METER PEDESTAL, L.P. BASE AND QUARTZITE BOX N OF BLDG "B"; ONE 1" PVC FROM INSIDE-CORNER OF PATIO TO WEST OF POOL BLDG, EAST ALONG NORTH SIDE OF PATIO; ONE 1" PVC FROM NORTH SIDE OF COMMONS PATIO TO EAST SIDE OF FIREPIT; FROM NORTH SIDE OF PATIO TO NORTH, AROUND CORNER OF FIREPIT, THEN WEST TO L.P. #D5; FROM #36 TO 37 TO 38 TO BOLLARD #43; 28 to 36; BOLL 44 TO LP 34; 42 TO 30' SE;
---	------	---

Comments: