

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20173149, Building Permit - Commercial

Address: 2801 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	Khanh Nguyen	Partial	Wednesday, October 25, 2017

Corrective Action Required

1	Misc	FLOOR&WALL FRAMING-OK
---	------	-----------------------

Comments: