

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161177, Building Permit - Commercial

Address: 500 NW MOORE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Wednesday, October 25, 2017

Corrective Action Required

1	Misc	-APPROVAL FROM THE FOLLOWING DEPT. REQUIRED: ELEVATOR INSPECTION
---	------	--

Corrective Action Required

2	Misc	- COMPLETE ALL FINISH SITEWORK INCLUDING HANDRAILS AT STEPS AT SW
---	------	---

Corrective Action Required

3	Misc	2010: INSTALL PERMANENT SPRINKLER HEAD AT OUTDOOR PATIO; SEAL PENETRATION
---	------	---

Corrective Action Required

5	Misc	ATTIC: - SEAL OPENINGS IN DRAFTSTOP WALLS - INSULATION TO BE FULL 12"
---	------	---

Occupancy Inspection - Water Utilities	Curtis Deason	Passed	Wednesday, October 25, 2017
---	---------------	--------	-----------------------------

Comments: