Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20160939, Building Permit - Commercial Address: 3320 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Above Ceiling Khanh Nguyen Partial Wednesday, October 25, 2017

Inspection

Corrective Action Required

1 Misc HARD-LID CEILING SPACE BELOW RATED CEILING:

-ZONE A&C CORRIDOR-OK

-ZONE B-OK

DROP-CEILING:

-ZONE A&C CORRIDORS OK

-ZONE B: FC CEILING PENETRATIONS ABOVE

KITCHEN/CORRIDOR/LAUNDRY AREA AND PENETRATIONS OF

SMOKE BARRIER WALL

_							
•	റ	m	m	Δ	n	ts	