

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161767, Building Permit - Commercial

Address: 813 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	Dale Carter	Partial	Wednesday, October 25, 2017

Partial Correction

1 Misc

OK TO COVER WHEN READY SHEAR WALLS AT: 1ST FLOOR;

BLDG #5: Roof nailing inspected & approved.

Comments: