



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No: PRCOM20172339 Date: October 27, 2017
Project Title: PLANET FITNESS Applicant:
Location: JSC ENGINEERS
300 SW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64063 24 SW Chipman Road
Type of Work: LEE'S SUMMIT, MO 64063
Occupancy Group:
Description: TENANT FINISH FOR NEW GYM Primary: (816) 272-5289

**invite planner to final to verify rtu screening
Construction Type: Type IIB (Unprotected)
Map Page: 195K

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:

An acceptance test of the system will be required prior to the final occupancy inspection. Contact the fire department to schedule testing. (816)969-1300

2. Plan revision

ACTION REQUIRED:

A revision has been made from the original submitted plan. Please notice on the attached sheet the revision made to the restrooms.

Horn/strobes were moved from the restrooms to the locker rooms. Strobe only to be installed in the restrooms.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.