
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20171770, Building Permit - Residential

Address: 1801 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sidewalk Inspection	Matt Munger	Partial	Friday, October 27, 2017

Informational

1 Matt Munger 10/27/2017 10:43 AM

Forms were set to meet ADA standards and gravel was compacted properly. Dan is going to use Isolation Joint material in the areas that we specified.

Comments:
