



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20173008	Date:	October 27, 2017
Project Title:	PINOT'S PALETTE	Applicant:	
Location:			
970 NW BLUE PKWY, Unit:B, LEES SUMMIT, MO 64086		KANSAS CITY FIRE AND SECURITY LLC	
Type of Work:		901 E LOULA ST	
Occupancy Group:	M	OLATHE, KS 66061	
Description:	TENANT FINISH FOR DESIGN		
STUDIO HOSTING WINE AND PAINTING CLASSES		Primary: (913) 780-5237	
Construction Type:	Type IIB (Unprotected)		
Map Page:	195A		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:

An Acceptance test of the new installed notification and activation devices will be required prior to the final occupancy inspection. Contact the fire department to schedule testing. (816)969-1300.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.