

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20171258, Building Permit - Commercial

Address: 2301 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|--------------------------|
| Rough Electrical Inspection - Commercial | Khanh Nguyen | Passed | Friday, October 27, 2017 |

| | | | |
|---|--------------|--------|--------------------------|
| Gas Piping Inspection - Commercial | Khanh Nguyen | Failed | Friday, October 27, 2017 |
|---|--------------|--------|--------------------------|

Corrective Action Required

| | | |
|---|------|--------------------------------------|
| 1 | Misc | RETEST WITH A WORKING PRESSURE GAUGE |
|---|------|--------------------------------------|

Comments: