

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20171319, Public Works Infrastructure Permit - Commercial
LBP V-A

Address: 2900 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Proof roll parking lot	Matt Munger	Partial	Monday, October 30, 2017

Informational

1 Matt Munger 10/30/2017 8:36 AM

I observed the dump truck roll back and forth over the Type 5 base material in the three dock areas on the west side of the building.

There was an area on the south side (last dock at the end) that dipped down while the truck was rolling over the Type 5 base material.

I informed Butch (Walter's Excavating) to fix that area.

Comments: