
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFR20170794, Public Works Infrastructure Permit - Residential
Eagle Creek 15th Plat

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Air Test	Tom Chandler	Passed	Monday, October 30, 2017

Informational

1 Tom Chandler 10/26/2017 Air tested Sanitary sewer main according to specs in Design and Construction manual. All sections passed for the amount of time specified for the length of line tested . 7:36 was the minimum amount of time for testing.

DEI-Sanitary Sewer - Vacuum	Tom Chandler	Passed	Monday, October 30, 2017
-----------------------------	--------------	--------	--------------------------------

Informational

2 Tom Chandler 10/26/2017 Vacuum testing completed for amount of time specified in the Design and Construction manual. Minimum time was 2:00. All manholes passed testing.

DEI-Curb - Proof Roll	Tom Chandler	Passed	Monday, October 30, 2017
-----------------------	--------------	--------	--------------------------------

DEI-Curb - Compression Strength	Tom Chandler	Partial	Monday, October 30, 2017
---------------------------------	--------------	---------	--------------------------------

Informational

1 Tom Chandler 10/30/2017 3:05 PM Olsson has been on-site to perform multiple test as various intervals for curb installation.

Comments:
