

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161765, Building Permit - Commercial

Address: 801 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Monday, October 30, 2017
Partial Correction 1 Misc		OK TO COVER WHEN READY SHEAR WALL SHEATHING AT STAIRWELLS 1ST LEVEL	
Partial Correction 2 Misc		OK TO COVER WHEN READY FRAMING & ENCLOSED SYSTEMS AT PRE-ROCK WALL SECTIONS FOR TUBS & SHOWERS AT: 4TH FLOOR; 3RD FLOOR; 2ND FLOOR; 1ST FLOOR;	
Partial Correction 3 Misc		OK TO COVER WHEN READY WALL AND CEILING FRAMING & ENCLOSED SYSTEMS AT: 4TH FLOOR UNITS AND SPACES INCLUDING STAIRWELLS AND ELEVATOR SHAFT; RC CHANNEL IN PLACE AT CEILINGS & WALLS 3RD FLOOR UNITS AND SPACES INCLUDING STAIRWELLS AND ELEVATOR SHAFT; [RC CHANNEL IN PLACE AT CEILINGS & WALLS 2ND FLOOR UNITS AND SPACES INCLUDING STAIRWELLS AND ELEVATOR SHAFT 1ST FLOOR UNITS AND SPACES INCLUDING GARAGES	
Rated Assembly Inspection	John Borns	Partial	Monday, October 30, 2017

Partial Correction

1 Misc

OK TO COVER RATED ASSEMBLIES AT STAIRWELLS:

SOUTH STAIRWELL:

FIRST FLOOR 1ST & 2ND LAYERS 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS;

SECOND FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X; 2ND LAYER PRE-ROCK AT TRUSS-JOIST BAYS;

THIRD FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER AT STAIRWELL FACE;

4TH FLOOR: 1ST & 2ND LAYER AT STAIRWELL FACE;

TOWER ABOVE 4TH FLOOR: **[1ST LAYER;**

NORTH STAIRWELL:

FIRST FLOOR 1ST & 2ND LAYERS 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS;

SECOND FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X; 2ND LAYER PRE-ROCK AT TRUSS-JOIST BAYS;

THIRD FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X GWB PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER AT STAIRWELL FACE;

4TH FLOOR: STAIRWELL 1ST LAYER; 2ND LAYER AT STAIRWELL FACE;

TOWER ABOVE 4TH FLOOR: [1ST LAYER;

Partial Correction

2 Misc

OK TO COVER RATED ASSEMBLIES PRE-ROCK AT ELEVATOR SHAFT:

FIRST FLOOR: 1ST & 2ND LAYERS PRE-ROCK AT TRUSS-JOIST BAYS;

SECOND FLOOR: 1ST LAYER PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X PRE-ROCK AT TRUSS-JOIST BAYS;

THIRD FLOOR: 1ST LAYER PRE-ROCK AT TRUSS-JOIST BAYS;

SHAFT FACE: [1ST LAYER FULL HEIGHT;

Partial Correction

3 Misc

SHAFT LID: [1ST LAYER;

OK TO TAPE, MUD, AND FIRESTOP 5/8" TYPE X PRE-ROCK GWB AT
TUB/SHOWER WALLS AT:

4TH FLOOR

3RD FLOOR

2ND FLOOR

1ST FLOOR

2ND-LAYERS:

2ND - 1ST FLR @ UNITSIDE CORR&STAIRWELL WALLS

2ND -4TH FLOOR

Partial Correction

4 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT CEILINGS AND
WALLS AT: 1ST FLOOR IT ROOM 1ST LAYER:

Comments: