

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20170812, Building Permit - Residential

Address: 1622 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Dale Carter	Passed	Tuesday, October 31, 2017

Gas Service Inspection - Residential	Dale Carter	Passed	Tuesday, October 31, 2017
---	-------------	--------	---------------------------

All Rough Inspection - Residential	Dale Carter	Not Ready	Tuesday, October 31, 2017
---	-------------	-----------	---------------------------

Corrective Action Required

1	Misc	Not ready - please provide approved plans onsite for inspection. Also please remove overgrown weeds at rear property line and address the following erosion control issues: Clean storm inlet; Clean street; R&R silt fence at rear; Extend erosion control at front, along curb to west of property, that is being used as entry drive to this property.
---	------	--

Gas Piping Inspection - Residential	Dale Carter	Passed	Tuesday, October 31, 2017
--	-------------	--------	---------------------------

Erosion Control	Dale Carter	Failed	Tuesday, October 31, 2017
------------------------	-------------	--------	---------------------------

Corrective Action Required

1	Misc	Clean storm inlet; Clean street; R&R silt fence at rear; Extend
---	------	---

erosion control at front, along curb to west of property, that is being used as entry drive to this property.

Comments: