

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20171543, Building Permit - Commercial

Address: 221 NW CHIPMAN RD, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	John Borns	Passed	Tuesday, October 31, 2017
<b>Gas Service Inspection - Commercial</b>	John Borns	Passed	Tuesday, October 31, 2017
<b>Gas Piping Inspection - Commercial</b>	John Borns	Passed	Tuesday, October 31, 2017

**Comments: GAS PIPING PRESSURE TEST HELD STEADY AT >= 10 PSI FOR >=10 MIN. RELEASE GAS SERVICE.**

**INSTALL STUD SHOES WHERE REQUIRED. INSTALL MISSING BOCA PLATES ON CONDENSATE PIPING. THEN OK TO COVER WHEN READY WOOD WALL AND CEILING FRAMING + ENCLOSED SYSTEMS ROUGH-IN.**