

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161180, Building Permit - Commercial

Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT,
MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Tuesday, October 31, 2017

Partial Correction

1	Misc	OK TO TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB AT CEILING AND WALLS AT: LINK CORRIDOR A111 SOUTH 36' + "B"-TO-COMMONS LINK; CORR 205 WALLS + LID; CORR A-305 LID & WALLS; CORR 405; CORR 219; CORR 207; LOBBY 205; CORR 219; LOBBY 224; LOBBY 309; CORR 305 S; CORR 307; CORR 319; UNITS/ROOMS: 201; 203; 204; 206; 209; 210; 212; 217; 218; 221; 222; 225; 226; 227; 228; 229; 231; 232; 233; 234; UNITS/ROOMS: 303; 304; 306; 308; 321; 322; 325; 326; 328; 332; 333; 301; 334; [310; 312; 313 EXCLUDING CHASE; 314; 315 EXCLUDING CHASE; 316; 317/318; 327; 329; 331; UNITS/ROOMS: 403; 404; 432; 433; UNITS/ROOMS: ABOVE CEILING AT BACKSIDE OF STAIRWELL WALL AT: 201; 222; 301; 322; 206;
---	------	---

Comments: