

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFR20170794, Public Works Infrastructure Permit - Residential  
Eagle Creek 15th Plat

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
DEI-Curb - Compression Strength	Tom Chandler	Partial	Tuesday, October 31, 2017

Informational

1 Tom Chandler 10/31/2017 1:56 PM Remainder of curb has been installed and throats completed by hand today as well.

DEI-Sanitary Sewer - Mandrel	Tom Chandler	Passed	Tuesday, October 31, 2017
------------------------------	--------------	--------	---------------------------

Informational

1 Tom Chandler 10/31/2017 1:54 PM Mandrel testing done on sanitary sewer main. All sanitary sewer testing has been completed and main has been flushed as well.

**Comments:**