

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20161765, Building Permit - Commercial  
Address: 801 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Wednesday, November 01, 2017

Partial Correction  
1 Misc

OK TO COVER RATED ASSEMBLIES AT STAIRWELLS:

SOUTH STAIRWELL:

FIRST FLOOR 1ST & 2ND LAYERS 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS;

SECOND FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X; 2ND LAYER PRE-ROCK AT TRUSS-JOIST BAYS;

THIRD FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER AT STAIRWELL FACE;

4TH FLOOR: 1ST & 2ND LAYER AT STAIRWELL FACE; 1ST LAYER AT CORRIDOR / UNIT FACE;

TOWER ABOVE 4TH FLOOR: WALLS 1ST LAYER; LID 1ST LAYER; WALLS 2ND LAYER; LID 2ND LAYER; **[LID 3RD LAYER + HAT CHANNEL; CEILING AT STAIRWELL ABOVE 4TH FLOOR LANDING 1ST LAYER; 2ND LAYER**

NORTH STAIRWELL:

FIRST FLOOR 1ST & 2ND LAYERS 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS;

SECOND FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X; 2ND LAYER PRE-ROCK AT TRUSS-JOIST BAYS;

THIRD FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X GWB PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER AT STAIRWELL FACE;

4TH FLOOR: STAIRWELL 1ST LAYER; 2ND LAYER AT STAIRWELL FACE; 1ST LAYER AT CORRIDOR / UNIT FACE;

TOWER ABOVE 4TH FLOOR: WALLS 1ST LAYER; LID 1ST LAYER; WALLS 2ND LAYER; LID 2ND LAYER; **[LID 3RD LAYER + HAT CHANNEL; CEILING AT STAIRWELL ABOVE 4TH FLOOR LANDING 1ST LAYER; 2ND LAYER;**

Partial Correction  
2 Misc

OK TO COVER RATED ASSEMBLIES PRE-ROCK AT ELEVATOR SHAFT:

FIRST FLOOR: 1ST & 2ND LAYERS PRE-ROCK AT TRUSS-JOIST BAYS;

SECOND FLOOR: 1ST LAYER PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X PRE-ROCK AT TRUSS-JOIST BAYS;

THIRD FLOOR: 1ST LAYER PRE-ROCK AT TRUSS-JOIST BAYS;

FOURTH FLOOR: 1ST LAYER AT CORRIDOR / UNIT FACE;

SHAFT FACE: 1ST LAYER FULL HEIGHT; **[2ND LAYER FULL HEIGHT;**

SHAFT LID: 1ST LAYER; **[2ND LAYER;**

Partial Correction  
3 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT CEILINGS AND WALLS AT:

1ST FLOOR IT ROOM 1ST LAYER; 1ST FLOOR SHEAR WALLS 1ST LAYER;

**Comments:**