

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20171228, Building Permit - Residential

Address: 617 NW LILAC PL, Unit:B, LEES SUMMIT, MO 64081619 NW LILAC PL, LEES SUMMIT, MO 64081615 NW LILAC PL, Unit:B, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Dale Carter	Partial	Thursday, November 02, 2017

Partial Correction

1	Misc	OK TO INSTALL INSULATION AND GWB AT UNITS: 615; 619; & 617.
---	------	---

CONTRACTOR NOTE AT UNIT 619: HONEYCOMBED CONCRETE BELOW NORTH END BEARING OF 31' WF STEEL BEAM AT BASEMENT EAST; POSSIBLE BEGINNING OF SHEAR FAILURE. PLEASE CHECK.

<b>Gas Piping Inspection - Residential</b>	Dale Carter	Passed	Thursday, November 02, 2017
--	-------------	--------	-----------------------------

**Comments:**