

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20172853, Public Works Infrastructure Permit - Commercial

Summit Eye Care

Address: 1621 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Air Test	Steve Robbins	Passed	Friday, November 03, 2017

Informational

1 Existing MH 1-1 to 1-2, 1-2 to 1-3, and 1-3 to 1-4 have all passed the air test of 7:34. Steve Robbins 11/03/2017 9:13 AM

Comments:
