

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20171570, Public Works Infrastructure Permit - Commercial
Control Services Company
Address: 3621 NE AKIN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Curb - Proof Roll	Matt Munger	Passed	Monday, November 06, 2017

Informational

1 Matt Munger 11/06/2017 3:36 PM

I observed the Contractor roll test the subgrade where curbs are to be put in. During the test I did not observe any rutting, pumping, or deformation.

DEI-Fire Line - Flush	Matt Munger	Partial	Monday, November 06, 2017
-----------------------	-------------	---------	---------------------------------

Informational

1 Matt Munger 11/06/2017 8:38 AM

No workers present to start the chlorination process, contacted Keith from Holthouse and he wanted to reschedule for 11/13/17.

Comments: