

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20162083, Public Works Infrastructure Permit - Commercial

WATER UTILITIES FACILITY

Address: 1200 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Miscellaneous PWORKS Inspection	Brice Lawson	Passed	Monday, November 06, 2017

Informational

- 1 Brice Lawson 11/06/2017 4:26 PM  
I met with Mark Green and Mike Pickard to go over the proposed pavement marking plan for SE Hamblen Rd. The proposed plan did not appear to be correct as the lines were shown to be yellow and should be white. I met with Casey Williams to let him know the City's expectations regarding the pavement markings and striping on Hamblen Rd.

Comments: