## **Development Services Department**

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## **Inspection Summary**

Permit #:PRCOM20152912, Building Permit - Commercial Address: 2751 NE DOUGLAS ST, Unit:T, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Khanh Nguyen Failed Tuesday, November 07, 2017

Codes Commercial

Corrective Action Required

1 Misc -APPROVAL REQUIRED FROM: PLANNING AND DEVELOPMENT

**ENGINEER INSPECTION** 

-EXTERIOR RECEPTACLE SHALL BE GFCI-PROTECTED

\*\*FRONT RECEPTACLE

-ALL BOXES RECESSED BEHIND THE COMBUSTIBLE WALL FINISH

SHALL HAVE SPARK-RING EXTENSIONS

\*\*THE SWITCHBOX

-AC UNIT: INSTALL CONDUCTORS RATED FOR WET LOCATION FOR THE WHIP CONDUCTORS; ID UNGROUNDED CONDUCTOR WITH

PROPER COLOR

\*\*THE NM CABLE INSIDE THE WHIP IS NOT RATED FOR WET

LOCATION

**Comments:**