

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20161097, Public Works Infrastructure Permit - Commercial
WILSHIRE AT LAKEWOOD MEMORY CARE
Address: 3320 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-ADA Inspection	Matt Munger	Passed	Tuesday, November 07, 2017

Informational

1 Matt Munger 11/07/2017 11:47 AM

Contractor corrected the issues that we had noticed in our initial inspection. The made sure there was 5ft of walking space and the cross slope was less than 2%.

Comments: