

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20173395, Building Permit - Commercial

Address: 3680 NE AKIN DR, Unit:134, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Commercial</b>	Khanh Nguyen	Failed	Wednesday, November 08, 2017

### Corrective Action Required

1	Misc	A LOW-HEEL INLET SHALL NOT BE USED AS WET-VENTED CONNECTION. FYI: YOU CAN USE A SIDE-HEEL INLET FITTING. REF IPC 706.4
---	------	--

### Comments: