

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20171570, Public Works Infrastructure Permit - Commercial  
Control Services Company  
Address: 3621 NE AKIN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

**Inspection Item:**

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
DEI-Commercial Curb Inspection	Matt Munger	Partial	Wednesday, November 08, 2017

**Informational**

- 1 Matt Munger 11/08/2017 2:47 PM  
I observed workers pouring the curbs with a machine. I verified that they are using KCM MB 4K mix and got the ticket. I asked that they use a blanket on the curbs due to the temperatures, the worker stated that the Contractor would take care of that. Also told him to make sure they have 3" deep contraction joints approximately at 10ft intervals. The finish that I could see was smooth as well.

**Comments:**