

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20161097, Public Works Infrastructure Permit - Commercial  
WILSHIRE AT LAKEWOOD MEMORY CARE  
Address: 3320 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

**Inspection Item:**

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
DEI-Site Visit	Matt Munger	Partial	Wednesday, November 08, 2017

Informational

1 Matt Munger 10/31/2017 12:54 PM  
Checked over the progress at the site.

Informational

2 Matt Munger 11/01/2017 11:27 AM  
Came out to check ADA Ramps on the north entrance of the site with Bob. The ADA ramp south of the north entrance needs to be re-done (the width of ramp is less than 5ft). The ramp on north side of the driveway approach for the north entrance has a crack and needs to be fixed. We spoke with Chuck Lancaster in regards to the concerns. I opened up the storm sewer manholes around the site and noticed in JB40 on page C1.01 appeared to have issues with the invert as well as the MH upstream holding water. Will bring another inspector out to get a second set of eyes on it. Spoke with Chuck about the manhole concerns and cleaning out any manholes with debris in them.

Informational

3 Matt Munger 11/08/2017 3:10 PM

Checked over the site to see if there was any other punch list items needing to be taken care of.

DEI-Grading/Excavation/Fill Inspection	Matt Munger	Passed	Wednesday, November 08, 2017
---	-------------	--------	------------------------------------

Informational

1 Matt Munger 11/08/2017 1:05 PM  
Dirt pile on the south side of the site was graded out and was seeded.

DE-ESC - (Vegetation/Ground Cover)	Matt Munger	Passed	Wednesday, November 08, 2017
------------------------------------	-------------	--------	------------------------------------

Informational

1 Matt Munger 10/26/2017 1:59 PM Sod had been put down along the east side along the road side as well on the south side of the property.

**Comments:**

---