

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20171570, Public Works Infrastructure Permit - Commercial  
Control Services Company  
Address: 3621 NE AKIN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Commercial Curb Inspection	Matt Munger	Partial	Thursday, November 09, 2017

Informational

- 1 Matt Munger 11/09/2017 10:23 AM  
Observed 3" deep contraction joints put in about every 10ft, smooth dowels at the ends of radius points. Informed the contractor to use the white cure and to make sure that they cover the curbs to protect them from the lower temps. He stated they will have the blankets out today.

Comments: