

Inspection Summary

Permit #: PRCOM20161058, Building Permit - Commercial
Address: 1200 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mike Copeland	Partial	Thursday, November 09, 2017

Partial Correction
1 Misc

ALL APPROVED EXCEPT KITCHEN / BREAK ROOM, REMOVE LOW
VOLTAGE WIRING FROM SPRINKLER LINES

Comments: