



**Certificate Number**

894F-413F72-1

**Inspection Date**

09/11/2017

**Expiration Date**

09/11/2022

## Lightning Protection Services

# MASTER LABEL® CERTIFICATE OF INSPECTION For LIGHTNING PROTECTION SYSTEMS

This certificate reports the findings of an inspection by Underwriters Laboratories of a lightning protection system. The inspection was conducted using all applicable sections of UL 96A, Installation Requirements for Lightning Protection Systems, Thirteenth edition, issued on 03/18/2016. The system was found to comply with these requirements at the time of inspection.

The following item(s) were omitted from the scope of the inspection:

Surge protection was not inspected. Surge protection devices are an integral component of a complete lightning protection system and should be provided on all incoming and exiting electric, power, data, and communication services.

**Structure:** MISSOURI INNOVATION CAMPUS  
**Address:** 1101 NW INNOVATION PARKWAY  
LEE'S SUMMIT, MO 64081  
UNITED STATES

**Installing Company:** PREFERRED LIGHTNING PROTECTION INC  
**Address:** 2100 E 1st St  
Maryville, MO 64468-3114

UL LLC makes no representations or warranties, expressed or implied, that the lightning protection system will prevent any loss or damage by a lightning event, or that the system will in all cases provide the protection for which it is installed or intended. The certificate is evidence that the installation complies with the installation requirements as outlined in the referenced standard. Valid certificates can be verified on UL's website: <https://lps.ul.com>.

UL LLC is not an insurer and does not assume any obligation or undertake to discharge any liability of the Listed Installing Companies or any other party for any loss, which may result from failure of equipment, incorrect installation, non-conformity with requirements, cancellation of this certificate or withdrawal of the Listed Installing Company from Listing by UL LLC's lightning protection program prior to the expiration date appearing on this certificate.

This certificate is only valid for 5 years. Any modification to electrical, mechanical or communication systems of the structure will affect lightning protection devices and may render protection afforded by this system ineffective. Any changes will invalidate our certificate earlier than the 5 year period.



UL and the UL logo are trademarks of UL LLC © 2016  
Unauthorized reproduction or alteration of this certificate constitutes fraud.  
This certificate is for reference use only.  
To verify Master Label® Certificate, please refer to website:  
<https://lps.ul.com>