

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20172464, Building Permit - Residential

Address: 2093 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822095 SW TIMBERTRACE LN, LEES
SUMMIT, MO 640822097 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822091 SW
TIMBERTRACE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Monday, November 13, 2017

Corrective Action Required

1	Misc	- SECURE AC WHIPS within 12" of box.
---	------	--------------------------------------

DEI-Sidewalk Inspection	Tom Chandler	Passed	Monday, November 13, 2017
--------------------------------	--------------	--------	---------------------------

Comments: