

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20172433, Building Permit - Residential

Address: 4709 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------|----------|---------------------------|
| Underslab Plumbing Inspection - Residential | Khanh Nguyen | Failed | Monday, November 13, 2017 |

Corrective Action Required

| | | |
|---|------|-------------------------------|
| 1 | Misc | EROSION CONTROL NOT COMPLIANT |
|---|------|-------------------------------|

| | | | |
|------------------------|--------------|--------|---------------------------|
| Erosion Control | Khanh Nguyen | Failed | Monday, November 13, 2017 |
|------------------------|--------------|--------|---------------------------|

Corrective Action Required

| | | |
|---|----------------------|--|
| 1 | DCM1 Erosion Control | EROSION CONTROL REQUIRED PER CITY REQUIREMENT. A GRAVEL FILTER SHALL BE PROVIDED AT DRIVEWAY ENTRANCE. |
|---|----------------------|--|

NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE.

Comments: