

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20171689, Building Permit - Commercial

Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Tuesday, November 14, 2017

Partial Correction

1 Misc

OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES/LOCATIONS: ROWS F THROUGH J, AND 17.3 THROUGH 16; STORAGE RM 1A226; RESTROOM 1A232; STORAGE RM 1A250; RESTROOM 1A217; CLEAN RM 1A218; EXTERIOR WALL AT 1A263 & 1A268; [261; 262.1; 262.2; 267; 218 COMPLETE; 263 COMPLETE; 210 COMPLETE; 258; 260; CORR 259; 209 S WALL; 213-215 E WALL; 266 N WALL; 266 W WALL B/F; **256 N WALL B/F;**

Comments: