

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20162603, Building Permit - Residential

Address: 308 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mike Copeland	Failed	Wednesday, November 15, 2017

Corrective Action Required

1	Misc	-OBTAIN IRRIGATION PERMIT -RE-GRADE REAR OF THE HOUSE, REQUIRED TO HAVE MINIMUM 6" CLEARANCE FROM SIDING TO GRADE AND 6" OF FALL AWAY FROM THE FOUNDATION WITHIN THE FIRST 10' INSTALLED ROCK AT THE REAR, CREATED A POND AND STILL DOES NOT HAVE 6" CLEARANCE FROM GRADE. DOES NOT HAVE 6" GREADE AWAY FROM THE FOUNDATION. RE-INSPECTION FEE
---	------	---

Comments: