

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20162575, Building Permit - Residential

Address: 304 SE MILL CREEK DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mike Copeland	Failed	Wednesday, November 15, 2017

### Corrective Action Required

1 Misc

-REAR GRADE NEEDS 6 INCHES CLEARANCE FROM SIDING  
INSTALLED ROCK, CREATED A POND FOR STORM WATER NEXT  
TO FOUNDATION AND DOESN'T HAVE 6" OF FALL AWAY FROM  
THE FOUNDATION.

### Comments: