

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFR20170794, Public Works Infrastructure Permit - Residential
Eagle Creek 15th Plat

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Miscellaneous PWORKS Inspection	Tom Chandler	Partial	Wednesday, November 15, 2017

Informational

- 1 Tom Chandler 11/15/2017 4:24 PM All the wyes to be corrected have been corrected. Backfill has been done. Will flush line again as well.

DEI-Miscellaneous PWORKS Inspection	Tom Chandler	Partial	Wednesday, November 15, 2017
-------------------------------------	--------------	---------	------------------------------

Informational

- 1 Tom Chandler 11/15/2017 9:49 AM Repairs are being made to wyes installed past the 45 degree maximum allowed angle. Will pour trench checks later today that are needed as well.

Comments: