

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161765, Building Permit - Commercial

Address: 801 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Wednesday, November 15, 2017

Partial Correction
1 Misc

OK TO COVER RATED ASSEMBLIES AT STAIRWELLS:

SOUTH STAIRWELL:

FIRST FLOOR 1ST & 2ND LAYERS 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 1ST LAYER AT CORRIDOR / UNIT FACE;

SECOND FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X; 2ND LAYER PRE-ROCK AT TRUSS-JOIST BAYS; 1ST LAYER AT CORRIDOR / UNIT FACE;

THIRD FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER AT STAIRWELL FACE;

4TH FLOOR: 1ST & 2ND LAYER AT STAIRWELL FACE; 1ST LAYER AT CORRIDOR / UNIT FACE; 2ND LAYER AT CORRIDOR / UNIT FACE;

TOWER ABOVE 4TH FLOOR: WALLS 1ST LAYER; LID 1ST LAYER; WALLS 2ND LAYER; LID 2ND LAYER; LID 3RD LAYER + HAT CHANNEL; 4TH LAYER

CEILING AT STAIRWELL ABOVE 4TH FLOOR LANDING 1ST LAYER; 2ND LAYER; 3RD LAYER + HAT CHANNEL; 4TH LAYER

NORTH STAIRWELL:

FIRST FLOOR 1ST & 2ND LAYERS 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 1ST LAYER AT CORRIDOR / UNIT FACE;

SECOND FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X; 2ND LAYER PRE-ROCK AT TRUSS-JOIST BAYS; 1ST LAYER AT CORRIDOR / UNIT FACE;

THIRD FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X GWB PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER AT STAIRWELL FACE;

4TH FLOOR: STAIRWELL 1ST LAYER; 2ND LAYER AT STAIRWELL FACE; 1ST LAYER AT CORRIDOR / UNIT 3XFACE; 2ND LAYER AT CORRIDOR / UNIT FACE;

TOWER ABOVE 4TH FLOOR: WALLS 1ST LAYER; LID 1ST LAYER; WALLS 2ND LAYER; LID 2ND LAYER; LID 3RD LAYER + HAT CHANNEL; 4TH LAYER
CEILING AT STAIRWELL ABOVE 4TH FLOOR LANDING 1ST LAYER; 2ND LAYER; 3RD LAYER + HAT CHANNEL; 4TH LAYER

Partial Correction
3 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT CEILINGS AND WALLS AT:

1ST FLOOR IT ROOM 1ST LAYER;
ST FLOOR SHEAR WALLS 1ST LAYER;

1ST FLOOR ELEVATOR MACHINE ROOM:
CEILING: 1ST LAYER; 2ND LAYER; **[3RD LAYER + HAT CHANNEL;**

1ST FLOOR SPRINKLER RISER ROOM: 1ST LAYER; **[WEST WALL 2ND LAYER;**

[1ST FLOOR UNITS, GARAGES, SPACES W/ 2ND LAYER AT STAIRWELLS, ELEVATOR

2ND FLOOR UNITS, SPACES AND STAIRWELLS: 1ST LAYER

3RD FLOOR SHEAR WALLS 1ST LAYER;

Comments: