
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20172853, Public Works Infrastructure Permit - Commercial

Summit Eye Care

Address: 1621 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Detention Basin	Steve Robbins	Partial	Thursday, November 16, 2017

Informational

- 1 The contractors are constructing the detention basin , they are installing the 4" perforated pipe wrapped in silt and covered in clean rock. This basin also gets a special dirt and sand mix.Steve Robbins 11/16/2017 2:36 PM

Comments:
