

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20173008, Building Permit - Commercial

Address: 970 NW BLUE PKWY, Unit:B, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Passed	Friday, November 17, 2017
Gas Service Inspection - Commercial	John Borns	Not Ready	Friday, November 17, 2017
Gas Service Inspection - Commercial	John Borns	Passed	Friday, November 17, 2017

Comments: VISUAL INSPECTION AND PRESSURE TEST OK. RELEASE GAS SERVICE.