



**LEE'S SUMMIT**  
**MISSOURI**



**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20173222	Date:	November 17, 2017
Project Title:	COLEMAN EQUIPMENT	Applicant:	
Location:	4101 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064		ALLIANCE FIRE PROTECTION LLC 130 W 9TH AVE STE 101 KANSAS CITY, MO 64116
Type of Work:			
Occupancy Group:	M		
Description:	NEW BUILDING FOR SALES OF TRACTOR & EQUIPMENT PARTS INCLUDING MAINTENANCE BAYS AND VEHICLE WASH	Primary:	(913) 888-0647
Construction Type:	Type IIB (Unprotected)		
Map Page:	175H		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Sprinkler Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

**ACTION REQUIRED:**

Field tests and acceptance testing of the system will be required prior to the final occupancy inspection. Contact the fire department to schedule tests. (816)969-1300.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**