

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20160939, Building Permit - Commercial

Address: 3320 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Monday, November 20, 2017

Partial Correction

1 Misc

APPROVALS FROM FOLLOWING DEPARTMENTS REQUIRED:
PLANNING, WATER, HEALTH

INTERIOR-OK

OUTSIDE:

-PAINT EXTERIOR GAS PIPING

-INSTALL LISTED FIRESTOPPING COLLARS FOR 3" PIPE

PENETRATIONS OF CEILING IN BOILER RM

-SECURE ALL MC IN BOILER RM WITHIN 12" OF ENCLOSURES

-ROOFTOP: TURN ON POWER TO GFCI RECEPTACLES; INSTALL
DAMPER FAT DRYER EXHAUST DUCT OUTLET; INSTALL GREASE
RESERVOIR FOR HOOD FAN; SECURE FLEXIBLE RACEWAY PER
CODE

Occupancy Inspection - Fire	Michael Weissenbach	Passed	Monday, November 20, 2017
--	------------------------	--------	---------------------------

Comments: