

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFR20171746, Public Works Infrastructure Permit - Residential
Manor at Stoney Creek 2nd - street, storm, sewer and water

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Vacuum	Brice Lawson	Partial	Monday, November 20, 2017

Informational

- 1 Brice Lawson 11/14/2017 6:45 AM
On 11-9-17 Bryan Byrd witnessed vacuum testin on the following manholes:

MH A-5 - Test Passed

MH A-6 - Test Passed

MH B-1 - Test Passed

MH B-2 - Test Passed

MH B-3 - Test Passed

Informational

- 2 Brice Lawson 11/20/2017 12:30 PM
Redford vacuum tested the following manholes:

MH E-1
Start test 10" mercury
End test 9.75" mercury
Test Duration 2.5 min
Test passed

MH C-1

Start test 10" mercury
End test 10" mercury
Test Duration 3 min
Test passed

MH C-2
Start test 10" mercury
End test 9.75" mercury
Test Duration 2.5 min
Test passed

DEI-Sanitary Sewer - Air Test Brice Lawson

Partial

Monday,
November
20, 2017

Informational

1 Brice Lawson 11/14/2017 6:52 AM

On 11-9-17 Bryan Byrd witnessed air testing on the following sanitary sewer line segments.

MH B-1 to MH B-2 Test Passed

MH B-2 to MH B-3 Test Passed

Informational

2 Brice Lawson 11/20/2017 12:24 PM

Redford performed air testing on the following line segments:

Cherne Gauge Cal. Date 10/31/17

MH E-1 to MH B-3

Start press. 3.9 psi

End press. 3.85 psi

Test Duration 7:34

Test Passed

MH B-3 to MH C-1

Start press 3.65 psi

End press 3.5 psi

Test Duration 23:01

Test passed

Corrective Action Required

3 Brice Lawson 11/20/2017 12:27 PM

Redford attempted to test the main segment from MH C-1 to MH C-2. The test did not start

as the minimum test pressure could not be achieved.

Make necessary corrections and test this line segment.

Comments:
